



Name of Sampler: Sayla Corner
Date Collected: 11/14/2019
School Name: Chinacum Creek Primery School
School Code: 2697
School District: Chimacum
School Address: 313 Ness Corner Rd, Port Hadlock WA 98339
School County: Jefferson
Number of Samples Collected: 35
School Point of Contact (POC): Henry Florschutz
POC Title: Maintenance Director
POC Email: Henry_florschutz@csd49.org
POC Phone Number: 360 302 5982
Date Samples Sent to Lab: 11/14/2019
Date Samples Received by Lab: 11/25/2019
Shipment Tracking Number: NA

All Aerators are replaced

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28764	other	other	Blank	<1	11/26/2019	
28765	FirstDraw	Tap	Kitchen sink	22	11/26/2019	<i>Fixture replaced Retest on 11/1/2020</i>
28766	FirstDraw	Tap	Kitchen double sink	8	11/26/2019	
28767	FirstDraw	Bubbler	Bubbler/bott filler combo near gym/breakfa: room	<1	11/26/2019	
28768	FirstDraw	BottleFiller	Bubbler/bott filler combo near gym/breakfa: room	<1	11/26/2019	
28769	FirstDraw	Tap	Music room	13	11/26/2019	<i>Flushed Retest on 11/1/2020</i>
28770	FirstDraw	Bubbler	Entrance bubbler/bottle filler combo	<1	11/26/2019	
28771	FirstDraw	BottleFiller	Entrance bubbler/bottle filler combo	<1	11/26/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28772	FirstDraw	Tap	Health room 105	11	11/26/2019	Flushed Retest 11/11/2020
28773	FirstDraw	Tap	Library office room 401	13	11/26/2019	Flushed Retest 11/11/2020
28774	FirstDraw	Tap	Staff lounge room 111	9	11/26/2019	
28775	FirstDraw	Tap	Room 301	14	11/26/2019	Flushed Retest 11/11/2020
28776	FirstDraw	Tap	Rm 303	3	11/26/2019	
28777	FirstDraw	Tap	Rm 304	12	11/26/2019	
28778	FirstDraw	Tap	Rm 306	3	11/26/2019	
28779	FirstDraw	Tap	Rm 308	4	11/26/2019	
28780	FirstDraw	Tap	Rm 305	8	11/26/2019	
28781	FirstDraw	Tap	Rm 309	3	11/26/2019	
28782	FirstDraw	Tap	Rm 311	6	11/26/2019	
28783	FirstDraw	Tap	Tap adjacent to rm 311	11	11/26/2019	
28784	FirstDraw	Tap	Rm 310	4	11/26/2019	
28785	FirstDraw	Tap	Rm 312	5	11/26/2019	Very low pressure
28786	FirstDraw	Bubbler	Bubbler/bott filler combo adjacent to boysâ rr; nearest rooms 311/312	<1	11/26/2019	
28787	FirstDraw	BottleFiller	Bubbler/bott filler combo adjacent to boysâ rr; nearest rooms 311/312	<1	11/26/2019	
28788	FirstDraw	Tap	Rm 204 low tap	7	11/26/2019	
28789	FirstDraw	Tap	Rm 204 high tap	10	11/26/2019	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
28790	FirstDraw	Tap	Rm 208	17	11/26/2019	Flushed, retested 1/11/20
28791	FirstDraw	Tap	Rm 210	9	11/26/2019	
28792	FirstDraw	Tap	Rm 207: left tap	21	11/27/2019	Flushed strainer replaced Retested 1/11/2020
28793	FirstDraw	Tap	Rm 207: right tap	10	11/27/2019	
28794	FirstDraw	Tap	Rm 211: double sink	7	11/27/2019	
28795	FirstDraw	Tap	Rm 211: low single sink tap	5	11/27/2019	
28796	FirstDraw	Tap	Kindergarten wing kitchenette sink	14	11/27/2019	Flushed Retested 1/11/2020
28797	FirstDraw	Bubbler	Kindergarten wing bub- bler/bottle filler combo	<1	11/27/2019	
28798	FirstDraw	BottleFiller	Kindergarten wing bub- bler/bottle filler combo	<1	11/27/2019	