



Name of Sampler: Sayla Comer
Date Collected: 01/11/2020
School Name: Chimacum Schools (Elementary/ buildings 200 and 100b)
School Code: 2697
School District: Chimacum
School Address: 91 W Valley Rd, Chimacum WA 98325
School County: Jefferson
Number of Samples Collected: 34
School Point of Contact (POC): Henry Florschutz
POC Title: Maintenance Director
POC Email: Henry_florschutz@csd49.org
POC Phone Number: 360 302 5982
Date Samples Sent to Lab: 01/11/2020
Date Samples Received by Lab: 01/14/2020
Shipment Tracking Number: NA

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31595	other		Blank	<1	01/14/2020	
31596	FirstDraw	Tap	Rm 503	3	01/14/2020	
31597	FirstDraw	Tap	Rm 504	4	01/16/2020	
31598	FirstDraw	Tap	Rm 505	2	01/14/2020	
31599	FirstDraw	Tap	Rm 506	1	01/14/2020	
31600	FirstDraw	Tap	Rm 502	3	01/16/2020	
31601	FirstDraw	Tap	Rm 507/512; tap next to dishwasher	7	01/14/2020	
31602	FirstDraw	Tap	Rm 511 conference	1	01/14/2020	
31603	FirstDraw	Tap	Rm 606	9	01/14/2020	
31604	FirstDraw	Tap	Rm 601	2	01/14/2020	
31605	FirstDraw	Tap	Rm 602	1	01/14/2020	
31606	FirstDraw	Tap	Rm 603	1	01/14/2020	
31607	FirstDraw	Tap	Rm 604	4	01/14/2020	
31608	FirstDraw	Tap	Rm 406	3	01/14/2020	
31609	FirstDraw	Tap	Rm 409: front tap	5	01/14/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31610	FirstDraw	Tap	Rm 409; tap next to microwave	8	01/14/2020	
31611	Flush	Tap	Rm 409: tap next to microwave	9	01/14/2020	
31612	FirstDraw	Tap	Rm 408: back wall left tap	4	01/14/2020	
31613	FirstDraw	Tap	Rm 408: back wall right tap	1	01/14/2020	
31614	FirstDraw	Tap	Rm 408: sink next to eyewash	4	01/14/2020	
31615	FirstDraw	Tap	Elementary food service double sink	7	01/14/2020	
31616	FirstDraw	PotFiller	Elementary food service double sink: pot filler/spring spout	11	01/14/2020	
31617	FirstDraw	Tap	Elementary food service single back sink	52	01/14/2020	
31618	Flush	Tap	Elementary food service single back sink	8	01/14/2020	
31619	FirstDraw	PotFiller	Elementary food service single back sink: pot filler/spring spout	11	01/14/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31620	FirstDraw	Tap	Elementary food service hand wash sink	7	01/14/2020	Water came out warm
31961	FirstDraw	Tap	Rm 730; staff workroom	5	01/14/2020	
31962	FirstDraw	Tap	Office health room; near rm 730	4	01/14/2020	
31963	FirstDraw	Tap	Band room	4	01/14/2020	
31964	FirstDraw	Tap	Multi purpose room: kitchen triple sink left tap	37	01/14/2020	
31965	FirstDraw	Tap	Multi purpose room kitchen triple sink right tap	11	01/14/2020	
31966	FirstDraw	PotFiller	Multi purpose room kitchen pot filler/spring spout at back in room with triple sink	5	01/14/2020	
31967	FirstDraw	Tap	Multi purpose room kitchen double sink	12	01/14/2020	

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
31968	FirstDraw	PotFiller	Multi purpose room kitchen double sink pot filler/spring spout	6	01/14/2020	