



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

The school is following recommended remediation to help reduce children's exposure to lead in drinking water, including fixture replacement with lead free certified fixtures and conducting follow up testing.

School District: Chimacum

School Name: Chimacum Elementary School

School Code: 2697

School Address: 91 W Valley Rd, Chimacum Washington 98325

Number of Samples Collected: 6

Date Collected: 2/22/2020

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
34396	other			<1	2/26/2020	NA
34397	FirstDraw	Tap	Kitchen double sink	5	2/26/2020	NA
34398	Flush	Tap	Kitchen double sink	2	2/26/2020	NA
34399	FirstDraw	Tap	Kitchen single sink	7	3/3/2020	NA
34400	Flush	Tap	Kitchen single sink	2	2/26/2020	NA
34401	FirstDraw	PotFiller	Kitchen single sink spring spout	3	2/26/2020	NA