



Office of Environmental Public Health Sciences
Washington State Department of Health
243 Israel Road Southeast, Tumwater Washington 98501

Lead Sample Collection Information

DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.

The school is following recommended remediation to help reduce children's exposure to lead in drinking water, including fixture replacement with lead free certified fixtures and conducting follow up testing.

School District: Chimacum

School Name: Chimacum High School

School Code: 3275

School Address: 91 W Valley Rd, Chimacum Washington 98325

Number of Samples Collected: 39

Date Collected: 02/22/2020

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
34357	other			<1	02/29/2020	NA
34358	FirstDraw	Tap	Kitchen double sink near dishwasher	6	02/29/2020	NA
34359	FirstDraw	PotFiller	Kitchen double sink near dishwasher: spring spout	5	02/29/2020	NA
34360	FirstDraw	Tap	Kitchen double sink near produce soak	40	02/29/2020	NA
34361	Flush	Tap	Kitchen double sink near produce soak	2	02/29/2020	NA
34362	FirstDraw	PotFiller	Kitchen double sink near produce soak: spring spout	15	03/12/2020	NA
34363	FirstDraw	Tap	Home Ec: sink 1	13	02/29/2020	NA
34364	FirstDraw	Tap	Home Ec: sink 2	16	02/29/2020	NA
34365	FirstDraw	Tap	Home Ec: sink 3	18	02/29/2020	NA
34366	FirstDraw	Tap	Home Ec: sink 4	9	02/29/2020	NA
34367	FirstDraw	Tap	Home Ec: sink 5	6	02/29/2020	NA
34368	FirstDraw	Tap	Home Ec: sink 6	7	02/29/2020	NA
34369	FirstDraw	Tap	Rm 104 office/rm 106a	5	03/13/2020	NA
34370	FirstDraw	Tap	Rm 106	46	02/29/2020	NA

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
34371	FirstDraw	Bubbler	100 hallway bubblers: low	<1	02/29/2020	NA
34372	FirstDraw	Bubbler	100 hallway bubblers: High	<1	02/29/2020	NA
34373	FirstDraw	BottleFiller	100 hallway bubblers: Bottle filler	<1	02/29/2020	NA
34374	FirstDraw	Tap	200 wing library workroom	6	03/01/2020	NA
34375	FirstDraw	Tap	Rm 207/life skills room	3	03/13/2020	NA
34376	FirstDraw	Tap	Rm 101 health room	6	03/01/2020	NA
34377	FirstDraw	Bubbler	Commons area double bubblers: low	1	03/01/2020	NA
34378	FirstDraw	Bubbler	Commons area double bubblers: High	<1	03/01/2020	NA
34379	FirstDraw	BottleFiller	Commons area double bubblers: Bottle filler	<1	03/01/2020	NA
34380	FirstDraw	Bubbler	Commons area single bubbler	<1	03/01/2020	NA
34381	FirstDraw	BottleFiller	Commons area double bubblers: Bottle filler	<1	03/01/2020	NA
34382	FirstDraw	Tap	Commons student store	3	03/01/2020	NA
34383	FirstDraw	Tap	Office workroom	9	03/01/2020	NA

(continued)

Program ID	Sample Type	Description	Location	Lead Results (ppb)	Analysis Date	Comments
34384	FirstDraw	Tap	Office health room	27	03/01/2020	NA
34385	FirstDraw	Tap	Staff lounge	6	03/01/2020	NA
34386	FirstDraw	Bubbler	Male locker room bubblers: low	<1	03/01/2020	NA
34387	FirstDraw	Bubbler	Male locker room bubblers: High	<1	03/01/2020	NA
34388	FirstDraw	BottleFiller	Male locker room bubblers: Bottle filler	<1	03/01/2020	NA
34389	FirstDraw	Bubbler	Female locker room bubblers: low	<1	03/01/2020	NA
34390	FirstDraw	Bubbler	Female locker room bubblers: High	<1	03/01/2020	NA
34391	FirstDraw	BottleFiller	Female locker room bubblers: Bottle filler	<1	03/01/2020	NA
34392	FirstDraw	other	Female locker room laundry room	<1	03/01/2020	NA
34393	FirstDraw	Bubbler	Gym foyer bubblers: low	1	03/01/2020	NA
34394	FirstDraw	Bubbler	Gym foyer bubblers: High	<1	03/01/2020	NA
34395	FirstDraw	BottleFiller	Gym foyer bubblers: Bottle filler	<1	03/01/2020	NA