

Chimacum High School					
Date/Results	2/29/2020	3/1/2020	3/12/2020	3/13/2020	Action Taken
Test	Lead	Lead	Lead	Lead	School Closed 3/17/2020
Samples Collected By	DOH	DOH	DOH	DOH	
Location:					
Kitchen double sink near dishwasher	6				
Kitchen double sink near dishwasher: spring sprout	5				
Kitchen double sink near produce soak - First Draw	40				Marked sink to flush. Replaced Faucet - 4/7/20.
Kitchen double sink near produce soak - Flush	2				
Kitchen double sink near produce soak: spring spout	TB		15		
Home Ec: sink 1	13				Replaced Faucet - 4/7/20.
Home Ec: sink 2	16				Replaced Faucet - 4/7/20.
Home Ec: sink 3	18				Replaced Faucet - 4/7/20.
Home Ec: sink 4	9				Replaced Faucet - 4/7/20.
Home Ec: sink 5	6				
Home Ec: sink 6	7				
Rm 104 office/rm 106a	TB			5	
Rm 106	46				Replaced Faucet - 4/7/20.
100 hallway bubblers: low	<1				
100 hallway bubblers: high	<1				
100 hallway bubblers: bottle filler	<1				
200 wing library workroom		6			
Rm 207/life skills room		TB		3	
Rm 101 health room		6			
Commons area double bubblers: low		1			
Commons area double bubblers: high		<1			
Comons area double bubblers: bottle filler		<1			
Commons area single bubbler		<1			
Commons area double bubblers: Bottle filler		<1			
Commons student store		3			
Office workroom		9			
Office health room		27			Replaced Faucet - 4/14/20.
Staff lounge		6			
Chimacum High School					
Date/Results	2/29/2020	3/1/2020			Action Taken
Test	Lead	Lead			School Closed 3/17/2020
Samples Collected By	DOH	DOH			
Location:					
Male locker room bubblers: low		<1			
Male locker room bubblers: high		<1			
Male locker room bubblers: bottle filler		<1			

Female locker room bubbler: low		<1					
Female locker room bubblers: high		<1					
Female locker room bubblers: bottle filler		<1					
Female locker room laundry room		<1					
Gym foyer bubblers: low		1					
Gym foyer bubblers: high		<1					
Gym foyer bubblers: bottle filler		<1					